

City of Lenox
2022 Water Quality Report
Georgia Water System ID #: GA0750002

Water System Contact:

Teresa Barber
Chris Yawn

Phone Number:

(Day) 229-546-4252
(Night) 229-546-7816

Summary of Water Quality Information

The **City of Lenox** drinking water system is owned and operated by the **City of Lenox**. The facility office is located at 15 East Colquitt Avenue in Lenox, Georgia. If there are ever any comments or inquiries to be made, please feel free to visit the City Hall or contact Teresa Barber, City Clerk, during regular working hours.

This report includes information about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. The **City of Lenox** is committed to providing your community with clean, safe, and reliable drinking water. For more information about your water or this report please call Teresa Barber. **A copy of this report will not be mailed to individual consumers but is available at City Hall upon request or by visiting cityoflenox.municipalimpact.com/water-quality-report.**

Your water comes from four (4) community *groundwater* wells within the City of Lenox. Well 101 is located on Broad Street, well 102 is located at the corner of Hayes Road and Gray Avenue, well 103 is located on Hwy 41 S., and well 104 is located on Brad Street. Three (3) of the wells derive water from the *Unconfined Coastal Plain aquifer*, while the fourth taps into the confined *Coastal Plain* aquifer, all of which provide ample volumes of water for your community. Any necessary treatment, such as the removal of contaminants or addition of disinfectant, is performed at the well sites. All well properties are protected from activities that could potentially contaminate the water source.

A **Wellhead Protection Plan (WHPP)** has been completed for the **City of Lenox** by the Georgia Department of Natural Resources Environmental Protection Division (GA EPD). The **WHPP** identifies sources of pollution which could potentially contaminate the water supply. There are no cited potential pollution sources within 15-foot control zone for any of the four (4) wells. Cited potential pollution sources within the 250-foot radius inner management zone of all four (4) wells include electrical transformers, utility poles, vehicle parking areas, sewer lines, access roads, secondary roads, and storm water run-off. Additional cited pollution sources for include abandoned vehicles for well 102; highway U.S. Route 41 for well 103; and agricultural fields and domestic septic systems for well 104. **The complete WHPP is available upon request at the facility office.**

The **City of Lenox** water system is tested for more than eighty (80) drinking water parameters on a periodic basis determined by the GA EPD Drinking Water Program and/or the United States Environmental Protection Agency. Sampling/testing schedules are based on initial contaminant level assessments and can be changed if deemed necessary. Waivers may be issued for the analysis of any of the mentioned compounds if analytical data shows that the distributed drinking water in this area is not vulnerable to contamination from these chemicals. Samples are collected from the water system for the analyses of volatile organic, synthetic organic, and inorganic compounds, lead, and copper at least once in a three (3) year cycle. Nitrate-nitrites, TTHM, and HAA5 levels are analyzed annually, and bacteriological contaminants are monitored monthly. The **City of Lenox** also conducts radionuclide testing at a frequency between three (3) and nine (9) years.

During 2022, the **City of Lenox** water system was tested for the presence of bacteriological content, nitrate-nitrite, volatile organic compounds, TTHMs, and HAA5s. **We are pleased to inform you that The City of Lenox did not have any violations of water quality parameters during 2022.** All detected contaminants are delineated in the accompanying charts. Any contaminants not listed in the accompanying charts had results less than the detection limits and/or maximum contaminant levels.

While your drinking water meets EPA's standard for arsenic, it has been shown to contain low levels of arsenic in routine sampling events. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

During the most recent lead and copper monitoring event, ten (10) representative locations throughout your community were sampled for the analyses of lead and copper. Detectable levels were found in some of the analyzed samples, indicating the presence of some service lines containing these contaminants. However, **NO** sampled site exceeded the *Action Level* limit for either lead or copper.

Lead and copper are metals naturally found throughout the environment in soil and water. These metals can also be found in lead, copper, or brass household plumbing pipes and fixtures. Even consumer products such as paints, pottery, and pewter can contain lead and/or copper. Corrosion or deterioration of lead or copper-based materials, as well as erosion of natural deposits can release these metals into the drinking water.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The **City of Lenox** is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Additionally, the following measures may be taken to minimize exposure to lead and/or copper:

- Use cold water for drinking or cooking.
- Do not cook with or consume water from the hot water faucet.
- Do not use hot water for making baby formula.
- Use only “lead-free” solder, fluxes and materials in new household plumbing and repairs.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the **EPA Safe Drinking Water Hotline (1-800-426-4791)**.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the **EPA Safe Drinking Water Hotline (1-800-426-4791)**.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include the following:

- **Microbial contaminants**, i.e., viruses and bacteria from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, i.e., salts and metals, can be naturally occurring or result from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and herbicides** may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, agricultural application, and septic systems.
- **Radioactive contaminants**, which can be naturally occurring or the result of oil/gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

The **City of Lenox** strives to maintain the highest standards of performance and quality possible. In order to maintain a safe and dependable water supply, improvements that benefit the community must be made. Please help keep these costs as low as possible by utilizing good water conservation practices.

DEFINITION OF TERMS AND ABBREVIATIONS USED IN THIS REPORT

Maximum Contaminant Level (MCL): “The highest level of a contaminant that is allowed in drinking water. MCL’s are set as close to the MCLG as feasible using the best available treatment technology.”

Maximum Contaminant Level Goal (MCLG): “The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG’s allow for a margin of safety.”

Secondary Maximum Contaminant Level (SMCL): Reasonable goals for drinking water quality. Exceeding SMCL’s may adversely affect odor or appearance, but there is no known risk to human health.

Maximum Residual Disinfectant Level (MRDL): “The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbiological contaminants.”

Maximum Residual Disinfectant Level Goal (MRDLG): “The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

TTHMs (Total Trihalomethanes): One or more of the organic compounds Chloroform, Bromodichloromethane, Chlorodibromomethane, and/or Bromoform.

HAA5s (Haloacetic Acids): One or more of the organic compounds Monochloroacetic Acid, Dichloroacetic Acid, Trichloroacetic Acid, Monobromoacetic Acid, and Dibromoacetic Acid.

CITY OF LENOX WATER SYSTEM
2022 WATER QUALITY DATA
WSID: GA0750002

The table below lists all the drinking water contaminants that have been detected in your drinking water. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The data presented in this table is from testing done during the year noted. The Federal Environmental Protection Agency (EPA) and the Georgia Department of Natural Resources Environmental Protection Division (EPD) require monitoring for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Parameters, values, and/or sources may vary.

| DETECTED INORGANIC CONTAMINANTS TABLE | | | | | | | | |
|---------------------------------------|-------|------------|------|----------------------------|---------------------|-------------|------------------|--|
| Parameter | Units | MCL [SMCL] | MCLG | Lenox Water System Results | Range of Detections | Sample Date | Violation No/Yes | Typical Source of Contaminant |
| Arsenic | ppb | 10 | ** | 6.1 | 0 to 6.1 | 2020 | No ¹ | Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes |
| Barium | ppm | 2 | 2 | 0.11 | 0.06 to 0.11 | 2020 | No | Erosion of natural deposits |
| Chlorine | ppm | 4 | 4 | 0.94 | 0.94 - 0.94 | 2022 | No | Water additive used for control of microbes |
| Fluoride | ppm | 4 [2] | 4 | 0.48 | 0.38 to 0.48 | 2020 | No | Erosion of natural deposits; water additive; discharge from fertilizer and aluminum factories |

| DETECTED ORGANIC CONTAMINANTS TABLE | | | | | | | | |
|-------------------------------------|-------|-----|------|----------------------------|---------------------|-------------|------------------|---|
| Parameter | Units | MCL | MCLG | Lenox Water System Results | Range of Detections | Sample Date | Violation No/Yes | Typical Source of Contaminant |
| Haloacetic Acids | ppb | 60 | ** | 1.1 | 1.1 to 1.1 | 2022 | No | By product of drinking water disinfection |
| THMs | ppb | 80 | ** | 9.4 | 9.4 to 9.4 | 2022 | No | By product of drinking water disinfection |

| OTHER DETECTED UNREGULATED CONTAMINANTS TABLE | | | | | | | | |
|---|-------|------------|------|----------------------------|---------------------|-------------|------------------|-------------------------------|
| Parameter | Units | MCL [SMCL] | MCLG | Lenox Water System Results | Range of Detections | Sample Date | Violation No/Yes | Typical Source of Contaminant |
| Sodium | ppm | ** | ** | 40 | 40 to 40 | 2020 | No | Erosion of natural deposits |

| LEAD AND COPPER MONITORING RESULTS | | | | | | | | |
|------------------------------------|-------|--------------|------|-----------------------|--------------------------------------|-------------|------------------|---------------------------------|
| Parameter | Units | Action Level | MCLG | Lenox 90th Percentile | # of sample sites above Action Level | Sample Date | Violation No/Yes | Typical Source of Contaminant |
| Lead | ppb | 15 | 0 | 1.9 | 0 of 10 | 2020 | No | Corrosion of household plumbing |
| Copper | ppm | 1.3 | 1.3 | 0.049 | 0 of 10 | 2020 | No | Corrosion of household plumbing |

| MICROBIOLOGICAL MONITORING RESULTS | | | | | | | | |
|------------------------------------|----------|-----|------|----------------------------------|------------------------------|-------------|------------------|--------------------------------------|
| Parameter | Units | MCL | MCLG | Lenox Number of Positive Samples | Positive Sample Date (Month) | Sample Year | Violation No/Yes | Typical Source of Contaminant |
| Total Coliform | Present/ | 1* | 0 | 2 | 7/2022 & 9/2022 | 2022 | No | Naturally present in the environment |
| E. coli | Absent | 0 | 0 | 0 | N/A | 2022 | No | Human and animal fecal waste |

| RADIONUCLIDES TABLE | | | | | | | | |
|-------------------------|-------|-----|------|----------------------------|---------------------|-------------|------------------|-------------------------------|
| Parameter | Units | MCL | MCLG | Lenox Water System Results | Range of Detections | Sample Date | Violation No/Yes | Typical Source of Contaminant |
| Alpha emitters | pCi/L | 15 | 0 | ND | N/A | 2021 | No | Erosion of natural deposits |
| Combined Radium 226/228 | pCi/L | 5 | 0 | 2.67 | 2.67 to 2.67 | 2021 | No | Erosion of natural deposits |

*Total Coliform Rule MCL= 1 positive sample for systems that collect <40 samples a month ** No established MCL, SMCL or MCLG

•N/A: Not applicable to this contaminant •ppb (ug/L): parts per billion or micrograms per liter •ppm (mg/L): parts per million or milligrams per liter •pCi/L: picocuries per liter, a measurement of radiation

•ND (Not Detected): By regulation, this substance or group of substances was tested for in our finished tap water; however, none was detected at the testing limit.

•Action Level (AL): "The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow."

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water."

¹ While your drinking water meets EPA standards, it does contain low levels of arsenic; see full Water Quality Report for information regarding possible health effects.